

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

From:

District Fire Officer,
East Godavari District,
Kakinada.

To

The District Educational Officer,
Kakinada
East Godavari District.

.....
Rc.No. 2785/DFO/EG/KKD/A2/2017, Dated: 21.10.2017.

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department-Eastern Region-East Godavari District- Issue No Objection Certificate for Occupancy to the existing Non-MSB of **Anaparthi Educational Society, , D.No. 4-263, Main Road, Anaparthi (V) & (M), East Godavari District - Issued.**

- Ref:**
1. Application through Mee-Seva Dt., 14.09.2017
 2. Inspection Committee report Rc.No. 78/ADFO /SFO/ ANP/2017. Dt., 06.10.2017.
 3. GO.Ms.No.154 MA & UD Dated. 13.03.2017
 4. Section. 13 as per AP Fire Service 1999.
 5. Circular Memorandum Rc.No. 3350/ Audit/NOC/2012 Dated. 09.03.2017 of the Director General, AP State Disaster Response & Fire Services, Andhra Pradesh, Vijayawada.
 6. Rc.No. 596/MSB Section/DGFS/2017, Dt., 03.07.2017 of Director General, AP State Disaster Response & Fire Services, Andhra Pradesh, Vijayawada

With references 1st cited the Management has applied for No Objection Certificate for Occupancy to **Anaparthi Educational Society, , D.No. 4-263, Main Road, Anaparthi (V) & (M), East Godavari District.**

Vide reference 2nd cited the Asst., District Fire Officer, Kakinada along with Station fire Officer, Anaparthi have inspected the building on 03.10.2017 and recommended to issue of No Objection Certificate for Occupancy to the existing Non-MSB of Anaparthi Educational Society, , D.No. 4-263, Main Road, Anaparthi (V) & (M), East Godavari District.

Particulars of the Educational Building

- a) Address of the Building : **Anaparthi Educational Society, , D.No. 4-263, Main Road, Anaparthi (V) & (M), East Godavari District.**
- b) Area of Plot/Ht. Of bldg : 10789.25 Sq.Mts /03.85 Mtrs of each block
- c) No. of blocks / Floors : Four Blocks / Ground floor
- d) Types of occupancy : Educational (B1)
- e) Year of Building plan approval : 2000

ii. The Management has provide the following Open spaces all around the Building.

Direction	Required as per Go.Ms.No. 119 MA&UD Dt:28.03.2017.	Provided in Blocks in Mtrs				Deficit in Blocks in Mtrs				Remarks
		East Block	West Block	North Block	South Block	East Block	West Block	North Block	South Block	
West (Front)	03.00 Mtrs	02.44	06.00	02.44	02.44	00.56	Nil	00.56	00.56	As per G.O.Ms. No. 154 MA & UD Dt, 13.03.2007
East	05.00 Mtrs	06.00	02.44	02.44	02.44	Nil	00.56	00.56	00.56	
North	05.00 Mtrs	06.00	06.00	06.00	06.00	Nil	Nil	Nil	Nil	
South	05.00 Mtrs	06.00	06.00	06.00	06.00	Nil	Nil	Nil	Nil	

iii. Floor-wise particulars: Educational

Blocks	Floor	Area in Sq.Mtrs	Occupancy	Occupant Load declared
East Block	Ground	1202.91	Educational	300
West Block	Ground	1202.91	Educational	300
North Block	Ground	771.46	Educational	193
South Block	Ground	771.46	Educational	193
Total		3948.74		986

iv The details of means of escape provided

Blocks	Highest No. of Students in a Floor	Width of means of escape required as per NBC.	Provided by the Builder	Deficit
East Block	300	$300 \times 6.5 / 1000 = 01.95$ Mtrs (Doors)	24×01.00 Mtrs = 24.00 Mtrs	Nil
West Block	300	$300 \times 6.5 / 1000 = 01.95$ Mtrs (Doors)	24×01.00 Mtrs = 24.00 Mtrs	Nil
North Block	193	$193 \times 6.5 / 1000 = 01.25$ Mtrs (Doors)	08×01.00 Mtrs = 08.00 Mtrs	Nil
South Block	193	$193 \times 6.5 / 1000 = 01.25$ Mtrs (Doors)	08×01.00 Mtrs = 08.00 Mtrs	Nil

5) Fire Safety Measures :


Sl. No	Fire Safety Measures	Required as per Table 07 of NBC of India 2016	Provided	Deficiency
1	Fire Extinguishers	40 Nos.	40 Nos.	Nil
2	Fire Buckets	40 Nos.	40 Nos.	Nil

5) The management has remitted fire precaution fee and penal interest Rs: 39,500/- (Rupees Thirty Nine Thousand Five Hundred only) Vide Challan no. 000004901 Dt. 07.09.2017 at SBI - Treasury, Anaparthi.

6. Therefore basing on the report of the inspection committee the No Objection Certificate for Occupancy is issued to **Anaparthi Educational Society**, , D.No. 4-263, Main Road, Anaparthi (V) & (M), East Godavari District.

7. This Occupancy Certificate is valid for One year from the date of issue and strictly applicable to the Fire Safety

Yours faithfully




(Ch. Ratnababu)
District Fire Officer,
East Godavari District,
Kakinada.

Copy to the Regional Joint Director, Kakinada.

Copy to the Station Fire Officer, Anaparthi.

Copy to the Asst., District Fire Officer, Kakinada.

Copy to the Anaparthi Educational Society, , D.No. 4-263, Main Road, Anaparthi (V) & (M), East Godavari





Challan Reference Form

GOVERNMENT OF ANDHRA PRADESH

CFMS Transaction ID: 40206592362020

Valid Upto: 31.03.2021

Treasury/PAO Code: 0320

STO: STO-Anaparthi

Service :

1088-Fee for Renewal NOCs

Major Head:

0070

Other Administrative Services

Sub-Major Head:

60

Other Services

Minor Head:

109

Fire Protection and Control

Group Sub-Head:

00

Not Applicable

Sub-Head:

81

Other Receipts

Detailed Head:

000

Not Applicable

Sub-Detailed Head:

000

NOT APPLICABLE

Charged/Voted:

V

Non-Contingency/Contingency:

N

Amount Rs:

26075.00

Amount In words Rs:

Twenty six thousand seventy five only

Purpose:

FIRE NOC OCCUPANCY PURPOSE FOR RENEWAL

Remitter's Name & Address:

THE ANAPARTHI EDUCATIONAL SOCIETY

MAIN ROAD
ANAPARTHI

Remitter's Mobile Number :

9848777747

DDO Code:

03201005001

S F O ANAPARTHI

Status

Payment Pending

Bank Ref No :

CPAATILAK8



'Branch Teller: Use SCR 008765 Deposit > Fee Collection > State Bank Collect'